

Debris Barriers

Date Inspected _____

Drainage System Feature	Potential Defect	Conditions When Maintenance Is Needed	Results Expected When Maintenance Is Performed Or Not Needed	<input checked="" type="checkbox"/>
General	Trash and Debris	Trash or debris that is plugging more than 20% of the openings in the barrier.	Barrier cleared to design flow capacity.	<input type="checkbox"/>
	Damaged/ Missing Bars	Bars are bent out of shape more than three inches.	Bars in place with no bends more than 3/4 inch.	<input type="checkbox"/>
		Bars are missing or entire barrier missing.	Bars in place according to design.	<input type="checkbox"/>
		Bars are loose and rust is causing 50% deterioration to any part of barrier.	Barrier replaced or repaired to design standards.	<input type="checkbox"/>
	Inlet/Outlet Pipe	Debris barrier missing or not attached to pipe.	Barrier firmly attached to pipe.	<input type="checkbox"/>