

Infiltration Trench

Date Inspected _____

Drainage System Feature	Potential Defect	Conditions When Maintenance Is Needed	Results Expected When Maintenance Is Performed Or Not Needed	<input checked="" type="checkbox"/>
General	Contaminants and Pollution	Any evidence of oil, gasoline, contaminants or other pollutants in or around facility. • Identify and remove source, AND • Report to Clark County Clean Water Illicit Discharge and Detection Elimination Program.	No contaminants or pollutants present.	<input type="checkbox"/>
	Observation Well	Sediment depth greater than one foot above stone aggregate or the surface inlet.	No sediment in infiltration trench.	<input type="checkbox"/>
	Drainage Slow	Decreased capacity that indicates slow drainage.	Verify facility design rate. Clean perforated drainpipe. Do not allow removed sediment and water to discharge back into the storm sewer.	<input type="checkbox"/>