

# Treatment Wetland

Date Inspected \_\_\_\_\_

Drainage System Feature	Potential Defect	Conditions When Maintenance Is Needed	Results Expected When Maintenance Is Performed Or Not Needed	<input checked="" type="checkbox"/>
General	Sediment Accumulation	Sediment accumulation exceeds design standards in presettling cell.	Remove sediment deposits in presettling cell.	<input type="checkbox"/>
	Water Depth	Water not retained to a depth of about 18 inches during the wet season.	Repair outlet so that water is retained in the wet swale.	<input type="checkbox"/>
	Wetland Vegetation	Vegetation becomes sparse and does not provide adequate filtration.	Determine cause of lack of vigor of vegetation and correct. Replant as needed.	<input type="checkbox"/>
		Nuisance plant species becomes abundant.	Nuisance plant species should be removed and desirable species should be planted.	<input type="checkbox"/>
	Trash and Debris Accumulation	Any trash and debris, which exceed five cubic feet per 1,000 square feet (this is about equal to the amount of trash it would take to fill one standard size garbage can). In general, there should be no visual evidence of dumping. If less than threshold, all trash and debris will be removed as part of next scheduled maintenance.	Remove trash and debris from wetland area.	<input type="checkbox"/>